

DECLARATION OF PERFORMANCE No.: II/2021

1. Unique identification code of the product type: FLEXIBLE ROLL-UP FIRE GATE AK120-1
 2. Intended use or uses: **Intended as internal gates, closing openings in building's vertical partitions of general construction objects, public and industrial buildings.**
 3. Manufacturer: **NGR TECHNOLOGIE Sp. z o.o.**
ul. Zielonogórska 8, 62-065 Grodzisk Wielkopolski
 4. Authorised representative: **n/a**
 5. Assessment and verification of constancy of performance: **1**
 6. Technical specification:
 - 6a. Harmonised standard: **EN 13241:2003+A2:2016; EN 16034:2014**
 - 6b. European approval document: **Certificate of constancy of performance**
No.: 1396-CPR-0203 issued 14.10.2021r.
- Notified Body: **N° 1396, FIRES, Batizovce, Slovakia**

7. Declared performance:

The essential characteristics of the construction product for the intended use or uses	Declared performance	Comments
Mechanical resilience	Satisfied	EN 13241:2003+A2:2016
Mechanical endurance	Satisfied	EN 13241:2003+A2:2016
Wind pressure resistance	Performance has not been determined	-
Sound insulation	Performance has not been determined	-
Fire resistance	E1 ₁₂₀ E2 ₁₂₀ E120 EW120	EN13501-2

8. Appropriate Technical Documentation or Specific Technical Documentation: **n/a**

The performance of the product identified above is consistent with the set of declared performance. This declaration of performance is issued, in accordance with Regulation (EU) No 305/2011, under the sole responsibility of the manufacturer identified above.

Date and place of issue

Grodzisk Wielkopolski, 14.10.2021

Signatory

"NGR TECHNOLOGIE" Sp. z o.o.
ul. Zielonogórska 8
62-065 Grodzisk Wilkop.
Tel. 61 44 45 165, fax 61 44 45 172
NIP 529-172-04-56, Regon 140567617
KRS 0000256477

PREZES ZARZADU
"NGR TECHNOLOGIE" Sp. z o.o.
Damian Wartocki